

# UL Type Examination Certificate

**Certificate**  
UL TEC-03002

**Issue date**  
2024-07-05

This is to acknowledge that

**NUHAS OMAN L L C**

RUSAYL INDUSTRIAL ESTATE  
PLOT NO 70, RD NO 2  
PO BOX 186 MUSCAT 124 OMAN

has had


**19/33kV 3CX400mm<sup>2</sup>  
AL/XLPE/CWS/PE-ST7/SWA/PE-ST7**

**19/33kV, AL 3CX400mm<sup>2</sup> XLPE MV Cable**

evaluated and meets the requirements of the standard

**IEC 60502-2:2014**

Test Report No. 4791201299-TR issued on 2024-06-11



Certification Manager  
Thomas Wilson

**UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark,  
Tel. +45 44 85 65 65, [www.ul.com](http://www.ul.com)**

This is to certify that the sample(s) of the Product described herein has been investigated and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL Solutions did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL Solutions has not established Follow-Up Service or other surveillance of the product. The Applicant/ Manufacturer are solely and fully responsible for any declaration of ongoing conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL Solutions' prior written approval.

# UL TYPE EXAMINATION CERTIFICATE

## TECHNICAL DETAILS

<b>Manufacturing site/location</b>	NUHAS OMAN L L C RUSAYL INDUSTRIAL ESTATE PLOT NO 70, RD NO 2 PO BOX 186 MUSCAT 124 OMAN
<b>Trademark</b>	-
<b>Ratings</b>	Rated voltage, $U_0/U (U_m)$ : 19/33 (36kV) Rated Maximum conductor temperature in normal operation: 90°C Rated conductor cross-section: 3C x 400mm <sup>2</sup> Refer to Type Examination summary for other details (4791201299-TR-S)
<b>Additional Information</b>	An additional evaluation to ADDC S-CAB-UMV-3CAL_00 was completed which included an evaluation for protrusions at the interfaces of non-metallic screens according to HD 605 S3